



NBS SPECIFICATION – ‘SOLUS’ SMOKE RELEASE HATCH

TESTED TO BS 7346:PART 1:1990 AT WARRINGTON FIRE GLOBAL SAFETY

MANUFACTURER:	Lareine Engineering Ltd, Unit 1, Armadale Industrial Estate Armadale, West Lothian, EH48 2ND E Mail: info@lareineengineering.com Website: lareineengineering.co.uk Tel: 01501 731600/ 731699 Fax: 01501 733828	
PRODUCT REFERENCE:	‘Solus’ Smoke Release Hatch.	
TYPE:	Hatches suitable for all types of flat /pitched roofs. They have been tested and are classed as non fragile Class B to ACR (M) 001:2005 Test for Fragility of Roofing Assemblies.	
FRAME:	Aluminium, aluminium to BS 1474:1987 Alloy 6063-T6.	
FINISH:	Mill Finish / Polyester Powder Coated.	
COLOUR:	Polyester powder coated to BS 6496 Interpon D36 range. Standard RAL colour.	
KERB:	FR 1 Lareine Engineering proprietary aluminium upstand 400mm high. This kerb is painted white internally. The upstand is insulated externally using 50mm Rockwool insulation, with insulation encapsulated in aluminium. Depth of upstand can be changed to suit your particular requirements. BU 1 Lareine Engineering proprietary aluminium upstand 150mm high. This kerb is painted white internally. The upstand is insulated externally using 50mm Rockwool insulation, with insulation encapsulated in aluminium. The flange width can be modified to meet your needs.	
LID:	TYPE A Insulated aluminium lid.	‘U’ VALUE 1.42 W/m²K
	TYPE B Double glazed glass lid comprising 8.0mm clear toughened outer, 16mm air gap, 6.4mm low ‘E’ laminate inner.	‘U’ VALUE 1.54 W/m²K
	TYPE C Clear or opal non fragile UV protected polycarbonate dome. (DUE TO BUILDING REGULATIONS THIS TYPE IS NOT AVAILBLE FOR SCOTLAND)	‘U’ VALUE Double skin 2.2 W/m²K Triple skin 1.35 W/m²K
FRAGILITY:	They have been tested and are classed as NON FRAGILE Class B to ACR (M) 001:2005 Test for Fragility of Roofing Assemblies.	
TESTED/MANUFACTURED TO:	All Rooflights are tested to: BS EN 6375-1:2009 Weather Tightness BS EN 1026 / 12207:2000 Air Permeability BS EN 1873 / 12208:2000 Water Tightness BS EN 12210:2000 Wind Resistance BS EN 1991-1 Snow Load BS EN ISO 140 Acoustic BS EN 1627-1630 Security	
ROOF OPENING:	1050mm X 1050mm (1m²) or other dimensions to meet your requirements.	
OPERATION:	24 Volt high temperature linear actuators.	
OTHER REQUIREMENTS:	Control panel with 240V/24V transformer, 1Amp/Hr battery backup in event of mains failure. Battery trickle charged to ensure 100% charge. Single zone with 1 fireman’s switch. Additional switch at top landing if required.	
FITTED TO MANUFACTURERS WRITTEN INSTRUCTIONS.		